



CB TEST CERTIFICATE

Ref. Certificate No.

IT-12203

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	IMQ S.p.A.		
Product:	Switch-disconnectors		
Applicant:	GIOVENZANA INTERNATIONAL BV	Strawinskylaan 1105 1077 XX AMSTERDAM	The Netherlands
Manufacturer:	ELECTRA ENGINEERING S.r.l.	VIA SPLUGA 2 23889 SANTA MARIA HOE' LC	Italy
Factory:	G.G.H. kft-Giulio Giovenzana Hungaria	Deak Ferenc ut 9 3036 GYONGYOSTARJAN	Hungary

Rating and principal characteristics: Ith-Ithe 40A (SQ032); Ith-Ithe 32A (SQ025); Ui 690V; Uimp 8kV; Icw 800A (1s); Icm 1500A; Conditional short-circuit current 10000A; 3P - 1P (additional neutral pole) - (See Test Report)

Trade mark (if any): GG GIOVENZANA



Model/Type reference: Series SQ032 - SQ025 (See Test Report)

Additional information:

Sample of product tested to be in conformity with IEC:
60947-1(ed.5)
60947-3(ed.3)

Test Report Ref. No: 02AM00045

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari *Mauro Casari*

Date of issue: 2012-09-13

