




CB TEST CERTIFICATE

Ref. Certificate No.

IT-12328

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	IMQ S.p.A.		
Product:	Switch-disconnectors		
Applicant:	GIOVENZANA INTERNATIONAL BV	STRAWINSKYLAAN 1105 1077 XX AMSTERDAM	The Netherlands
Manufacturer:	ELECTRA ENGINEERING SRL	Via Spluga, 2 23889 S. MARIA HOE' LC	Italy
Factory:	SCAMEAST SRO	NABREZIE ORAVY 628/3 02601 DOLNY KUBIN	Slovakia
Rating and principal characteristics:	2P; 3P; 3P+N - lth 32A; 40A - lthe 32A; 40A - lcm 1500A - lcw 400A (1s) - Uimp 4kV - Ui 690V (see Test Report on page 43)		
Trade mark (if any):	GG (logo) GIOVENZANA 		
Model/Type reference:	Series SE32 - SE16 (see Test Report on pages 43 and 44)		
Additional information:	This CBTC supersedes the preceding one No. IT-3780 of 2004-06-22		
Sample of product tested to be in conformity with IEC:	60947-1(ed.5);am1 60947-3(ed.3);am1		
Test Report Ref. No:	02AM00046		

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2012-10-29

