



CB TEST CERTIFICATE

Ref. Certificate No.

IT-12329

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ S.p.A.


Product: Switches

Applicant: GIOVENZANA STRAWINSKYLAAN The Netherlands
INTERNATIONAL BV 1105
1077 XX
AMSTERDAM

Manufacturer: ELECTRA Via Spluga, 2 Italy
ENGINEERING SRL 23889 S. MARIA HOE'
LC

Factory: G.G.H. KFT-GIULIO DEAK FERENC UT 9 Hungary
GIOVENZANA 3036
HUNGAR GYONGYOSTARJAN

Rating and principal characteristics: 2P; 3P; 4P - Ith 32A; 40A; 50A - Ithe
25A; 32A; 40A - Icm 2840A - Icw 500A
(1s) - Uimp 6kV - Ui 690V (see Test
Report on page 36)

Trade mark (if any): GG (logo) GIOVENZANA


Model/Type reference: Series C.25 - C.32 - C.40 (see Test Report on pages 37 and 38)

Additional information: This CBTC supersedes the preceding one no. IT-8347 of 2009-05-15

Sample of product tested to be in conformity with IEC: 60947-1(ed.5);am1
60947-3(ed.3);am1

Test Report Ref. No: MAIMQAGCERMI120072137-01

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari *Mauro Casari*

Date of issue: 2012-10-29

