



## CB TEST CERTIFICATE

Ref. Certificate No.

IT-12331

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ S.p.A.


Product: Switches

Applicant: GIOVENZANA STRAWINSKYLAAN The Netherlands  
INTERNATIONAL BV 1105  
1077 XX  
AMSTERDAM

Manufacturer: ELECTRA Via Spluga, 2 Italy  
ENGINEERING SRL 23889 S. MARIA HOE'  
LC

Factory: G.G.H. KFT-GIULIO DEAK FERENC UT 9 Hungary  
GIOVENZANA 3036  
HUNGAR GYONGYOSTARJAN

Rating and principal characteristics: 2P; 3P; 4P - Ith 16A; 20A; 25A - Ithe  
12A; 16A; 20A - Icm 1200A - Icw 300A  
(1s) - Uimp 4kV - Ui 690V (see Test  
Report on pages 38 to 40)

Trade mark (if any): GG (logo) GIOVENZANA  


Model/Type reference: Series PX20, PX16, PX12 (See Test Report on pages 41 and 42)

Additional information: This CBTC supersedes the preceding one No. IT-8314 of 2009-05-05

Sample of product tested to be in conformity with IEC: 60947-1(ed.5);am1  
60947-3(ed.3);am1

Test Report Ref. No: MAIMQAGCERMI120072137-01

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.  
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2012-10-29

