



CB TEST CERTIFICATE

Ref. Certificate No.

IT-12332

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ S.p.A.


Product: Switch-disconnectors

Applicant: GIOVENZANA STRAWINSKYLAAN The Netherlands
INTERNATIONAL BV 1105
1077 XX
AMSTERDAM

Manufacturer: ELECTRA Via Spluga, 2 Italy
ENGINEERING SRL 23889 S. MARIA HOE'
LC

Factory: G.G.H. KFT-GIULIO DEAK FERENC UT 9 Hungary
GIOVENZANA 3036
HUNGAR GYONGYOSTARJAN

Rating and principal characteristics: 2P; 3P; 3P+N; 4P - Ith 63A; 86A - Ithe 63A; 86A - Uimp 8kV - Ui 690V (see Test Report on page 28)

Trade mark (if any): GG (logo) GIOVENZANA


Model/Type reference: Series SE63 - SE80 (See Test Report on pages 29 and 30)


Additional information: This CBTC supersedes the preceding one No. IT-3779 of 2004-06-22

Sample of product tested to be in conformity with IEC: 60947-1(ed.5);am1
60947-3(ed.3);am1

Test Report Ref. No: MAIMQAGCERMI120072167-01

This CB Test Certificate is issued by the National Certification Body:

IMQ S.p.A.
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari 

Date of issue: 2012-10-29

