



产品认证证书

证书编号: CQC2018010305042520

申请人名称及地址

Giovenzana International B. V.
Strawinskylaan 1105-1077XX Amsterdam, NL

制造商名称及地址

海立电气股份有限公司中和厂
台湾新北市中和区中山路二段 359 巷 5 号 5 楼

生产企业名称及地址

海立电气股份有限公司中和厂 (V055938)
台湾新北市中和区中山路二段 359 巷 5 号 5 楼

产品名称和系列、规格、型号

限位开关

FTN□□□□: Ui:500V; Uimp:2.5kV; Ith:10A; AC-15: Ue/le:400VAC/4A; DC-13: Ue/le:24VDC/6A;
IP67; 型号解释见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 09 月 18 日 有效期至: 2022 年 03 月 30 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0395950



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2018010305042520

NAME AND ADDRESS OF THE APPLICANT

Giovenzana International B. V.
Strawinskylaan 1105-1077XX Amsterdam,NL

NAME AND ADDRESS OF THE MANUFACTURER

Highly Electric Co.,LTD.Chung Ho Factory
5F/5,2-359,Zhongshan Road,,Chung-Ho Distric,Xin-Bei City,Taiwan

NAME AND ADDRESS OF THE FACTORY

Highly Electric Co.,LTD.Chung Ho Factory (V055938)
FL, 5, No.5,Lane359,Sec.2,chung-Shan Road,Chung-Hocity,Taipei Hsien,Taiwan.

PRODUCT NAME, MODEL AND SPECIFICATION

Limit switch

FTN□□□□: Ui:500V; Uimp:2.5kV; Ith:10A; AC-15: Ue/Ie:400VAC/4A; DC-13: Ue/Ie:24VDC/6A; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Sep.18,2020

Valid until: Mar.30,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0395950